

30-Day UST Inspection Log per 310 CMR 80.35(2)		Where applicable, staple Automatic Tank Gauge, Liquid Status &/or Monthly Test Report here: Mass DEP Id #	
Inspector Name:		Operator ID#:	Inspection Date/Time
Inspector Type:	Class A Operator	Class B Operator	Class A/B Operator
Other inspector under the direction of a Class A, B or A/B Operator: Yes No			
Name of Class A, B or A/B Operator directing inspection:		Operator ID#:	
1. Electronic Monitoring Equipment (as applicable: interstitial space monitoring, in-tank monitoring, liquid sensors monitoring sumps and spill buckets, and impressed current cathodic protection rectifiers)		Result	If "No", why and suggested repair
A. Is all electronic monitoring equipment "on"?		Yes No	Date repaired
B. Is all electronic monitoring equipment "operating properly" (e.g. no alarms) ?		Yes No	
C. If required, has a monthly test log been printed?		Yes No NA	
2. Spill Buckets, Covers and Sensors		 USTinspection.com ASTinspection.com ph (781) 383-8783 ph (781) 383-8784 5 Allen Street Newburyport, MA 01950	
A. Are all spill buckets clean and free of solid and liquid material?		Yes No	
B. Are all spill buckets and covers free of corrosion, deterioration, cracks and holes?		Yes No	
C. If applicable, are all spill bucket sensors positioned in accordance with manufacturer's specifications?		Yes No	
D. Are there obstructions in the fill pipes? (Remove if present.) Are fill caps secure?		Yes No	
C. For double wall spill buckets with interstitial monitor, is there any leakage in interstitial area?		Yes No NA	
3. Fill cover color-coding			
A. Are all grade-level fill covers color-coded in compliance with API, RP 1637?		Yes No	