

ASTRO-CHEM LAB, INC.

4102 2nd Ave. West

Williston, North Dakota 58802-0972
P.O Box 972

Phone: (701) 572-7355

WATER ANALYSIS REPORT

Sample Number: W-15-6538

Date of Analysis: 08/18/2015

Company: Ridgeview Park, LLC.

City: Tiburon

State: CA

Well Number: Dore Water

Date Received: 08/17/2015

Depth:

Sample Source:

Location:

Section:

Twp:

Rng:

County:

Distribution: Distribution List

Conductivity @ 77 °F

1341.00 uMHOS/cm

pH

8.25

Residual Sodium Carbonate

-1.80 MEQ/L

Hardness

29.2 Grains/gal

Sodium Adsorption Ratio

2.33

Hardness

500 mg/L

Total Dissolved Solids (Calculated)

1083 mg/L

Sodium Chloride (Calculated)

76 mg/L

CATION	MEQ/L	mg/L	ANION	MEQ/L	mg/L
CALCIUM	5.0	100	CHLORIDE	1.3	46
MAGNESIUM	5.0	61	CARBONATE	0.0	0
SODIUM	5.2	120	BICARBONATE	8.2	500
IRON	0.0	0.0	SULFATE	5.1	245
POTASSIUM	0.2	6	NITRATE-N	0.3	4.8

Remarks: Sampled 8-17-15 (9:30 AM)

Analyzed By: C. Jungels