

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 13/5/24

It is certified that an inspection team headed by DWS District water testing Lab

(Name of Officers with designation) from Bandoax, Udaipur PHED

inspected the Garia Academy (Model), Athrabala,

(Name & Address of the school) on 13/5/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1(3)/DWS/DIST/LAB/UDP/576 dated 15/5/2024

of DWS District water testing Lab (PHED Lab) certified that the

Garia Academy (Model) (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 13/05/2025

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: Athrabala PH

To  
The Principal In-charge  
Garia Academy (Model)  
(Name & Address of the Institution)

Medical Officer  
Athrabhola PHC, Udaipur  
Gomati, Tripura

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Surjya Bahari Jamatia  
(Surjya Bahari Jamatia)  
Manager  
Garia Academy (M)

Iyoti Jamatia  
Principal  
Garia Academy (Model)

GOVERNMENT OF TRIPURA  
DWS DISTRICT WATER TESTING LABORATORY, BANDOAR  
UDAIPUR, GOMATI TRIPURA



**TEST REPORT**

**Name & address of the customer**

To  
The Principal In-Charge  
Garia Academy (model)  
H.Q.Garia Hathai, Atharabla,  
Udaipur, Gomati Tripura

Report No:- 1(3)/DWS/DIST/LAB/UDP/576

Date:- 15/05/2024

Sample ID:- U1175182S20048271

Date of receipt of sample:- 13/05/2024

Date of start of Analysis:-14/05/2024

Date of end of Analysis:- 15/05/2024

Reference no:-No.F.GA(M)/33/DWS/2024/1331

Date:-13/05/2024

*We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results –*

1	Description of sample(as declared by the customer)	Clear Water
	Volume of Sample Received	1lit
2	Sample mark(if any given by the customer)	NA
3	Date of sampling declared by customer	13/05/2024
4	Place of sampling declared by customer	Garia Academy (model)
5	Environmental conditions during sample Receipt	Temp: 25 °C Humidity 65 %

**ANALYSIS OF RESULT**

Sl No.	Characteristic	Desirable limit (BIS 10500:2012)	Permissible limit (BIS 10500:2012)	Method of test	Result
1	Colour in Hazen Unit	5	15	APHA 23 <sup>rd</sup> edition 2120 B	—————
2	Odour			APHA 23 <sup>rd</sup> edition 2160 C	Unobjectionable
3	Taste			APHA 23 <sup>rd</sup> edition 2160 C	Unobjectionable
4	Turbidity in NTU	1	5	APHA 23 <sup>rd</sup> edition 2130 B	0.12
5	PH	6.5 – 8.5	No relaxation	APHA 23 <sup>rd</sup> edition 4500 H <sup>+</sup> B	6.81
6	TDS in mg/L	500	2000	APHA 23 <sup>rd</sup> edition 2540 C	-
7	Total Alkalinity in mg/L as CaCO <sub>3</sub>	200	600	APHA 23 <sup>rd</sup> edition 2320 B	64
8	Total Hardness in mg/L as CaCO <sub>3</sub>	200	600	APHA 23 <sup>rd</sup> edition 2340 C	52
9	Iron in mg/L as Fe	1.00	No relaxation	APHA 23 <sup>rd</sup> edition 3500 Fe B	0.19
10	Chloride in mg/L as Cl	250	1000	APHA 23 <sup>rd</sup> edition 4500 Cl(-)B	20.49
11	Calcium in mg/L as Ca	75	200	APHA 23 <sup>rd</sup> edition 3500 Ca B	14.42
12	Magnesium in mg/L as Mg	30	100	APHA 23 <sup>rd</sup> edition 3500 Mg B	11.07

Report Tested by

*[Signature]*  
15/05/24

Name & designation

Authorized Signatory

*[Signature]*  
15.5.24

Name & designation

1. The results relate only to the items tested.
2. The test report shall not be reproduced except in full without the permission of District level water testing laboratory, Bandoar, Gomati District.
3. The reserved part of samples shall be retained for 15 days from the date of issue of the test report.
4. The report shall not be used for any advertisement or legal purpose.

**Remarks:** Based on the Parameters tested the Results of the sample is following the necessary requirements as per IS 10500:2012.

**END OF REPORT**

*[Signature]*  
(Surjya Behari Jamatia)  
Manager

*[Signature]*  
Principal

Report No:- 1(3)/DWS/DIST/LAB/UDP/576  
Sample ID:- U1175182S20048271

### ANALYSIS OF RESULT

Sl No	Characteristic	Acceptable limit	Permissible limit	Method of test	Result
1	MPN of total coliform in 100 ml	No relaxation	No relaxation	Mac conke brouth/FTK	NF

Report Analysed by

*Surya Behari Jamatia*  
15/11/2021

Name & designation

Signature of the authorized

*Iyoti Jamatia*

Name & designation

### END OF REPORT

DWS DISTRICT LEVEL WATER TESTING LABORATORY, BANDOUR UDAIPUR, GOMATI TRIPURA				
DOC No:- DLWTL - QP -22:13	Test report (Based on ISO/IEC17025/2017)			
Issue No:- 01	Issue date 15.11.2021	Amend No:- 00	Amend date:-	Page No:- 3 of 3

*Surya Behari Jamatia*  
(Surya Behari Jamatia)  
Manager  
Garia Academy (M)  
H.Q-Garia Hathai, Atharabari  
Udaipur, (G) Tripura.

*Iyoti Jamatia*  
Principal  
Garia Academy (Model)

GOVERNMENT OF TRIPURA  
DWS.DISTRICT LABORATORY, BANDOUR.  
UDAIPUR,GOMATI TRIPURA

This is to Certify that as per test Report of Water sample ID-U1175182S20048271 and Report No-1(3)/DWS/DIST/LAB/UDP/576 Date-15/05/2024 which the water sample is sent by Goria Academy ( model) Atharabla is fit and safe for Drinking Purpose .

*h*  
*15.5.24*  
CHINMOY ROGA  
IN-CHARGE

DWS DISTRICT LABORATORY , BANDOUR  
UDAIPUR,GOMATI,TRIPURA

*Surjya Behari Jamatia*  
(Surjya Behari Jamatia)  
Manager  
Garia Academy (M)  
H.Q-Garia Hathai, Atharabla  
Udaipur, (G) Tripura.

*Iyoti Jamatia*  
Principal  
Garia Academy (Model)  
HQ-Garia Hathai, Atharabla,  
Udaipur (G), Tripura.