NOISE ATTENUATION

Noise levels were measured at a distance of three feet from the acoustical enclosure of a KG-2 gas turbine generator. The generator was operated at load with auxiliary equipment running.

Equipment:

KG-2 Gas Turbine Generator

KDP Outdoor Enclosure

KDP Industrial Intake Filter and Elbow Silencer

KDP Industrial Exhaust Silencer

Octave Band (Hz)

·	63	125	250	50 <u>0</u>	1000	2000	4000	8000	sum
Noise level at 3 feet (dB)	88	82	83	82	_. 77	79 -	81	72	86 dBA
Noise Level at 50 feet (dB)	82	77	69	67		71	69	69	76 dBA