





NAMEPLATE

GE POWER VAC BREAKER		TYPE VB1 4.76-40-3 (3)	
RATED MAX VOLTAGE 4.76 KV		SER. NO. 0197A2055***	
RATED AMP. 1200	RATED VOLTAGE RANGE FACTOR 1.00	IMPULSE WITHSTAND 60 KV	INT TIME 3 CYC
RATED SHORT CIRCUIT AMPS 40 KA	CLOSE & LATCH CAPABILITY AMP. 104 Peak KA		
CLOSE COIL 0209B8103G009	VOLTS 125VDC	CLOSING AMPS 6.0	VOLT RANGE 100-140
TRIP COIL-1 0209B8104G007	VOLTS 125VDC	TRIPPING AMPS 10.5	VOLT RANGE 70-140
TRIP COIL-2	VOLTS	TRIPPING AMPS	VOLT RANGE
CHARGING MOTOR 0177C5050G004	VOLTS 125VDC		
CONNECTION DIAGRAM 0209B8267P002	WT. 470lbs	MECH TYPE ML-18	DATE MFG
VAC.INTER.TYPE:44B1	REQ.: 348-97781-MV-BUR	S.O.: 101957010	1
ORDERING NO. PVEL1A1A1A2202H1A1	CAP SWITCHING AMPS NO RATING		

CAUTION:BEFORE INSTALLING OR OPERATING READ INST. GEK86132 GE INDUSTRIAL SYSTEMS WEST BURLINGTON, IOWA 52655 USA

