





4" X 6"
APPROVED
LABEL



WATERTIGHT SEAL



GROVE CONCRETE & SUPPLY, INC.
18426 DURAND AVENUE P.O. BOX 363
UNION GROVE, WISCONSIN 53182
(262) 878-2030 FAX (262) 878-4222
GroveConcrete.com

NOTES:

1. GALLONS PER INCH:
771 COMPARTMENT - 18.37 gal/in.
2. REINFORCED CONCRETE 4,000 PSI
MIN.
3. (GASKETED 4" OPENINGS) PRESS
SEAL, TUFF TIGHT OR EQUAL.
4. ALL BAFFLES & FILTERS TO BE
INSTALLED TO MEET STATE &
LOCAL CODES.

GALLON (771)
SEPTIC TANK, HOLDING, PUMP

FOR ANY MODIFICATIONS CALL
GROVE CONCRETE

DRAWN BY:
RAY

DATE:
3/2/16

SCALE:
NTS

EST. WIEGHT:
7,000 LBS.

VERSION:
00002

DWG. #
TNK-771-VEN-VER2

ILL. APPROVAL # 114
STATE OF WIS. APPROVED

THIS DRAWING AND THE INFORMATION CONTAINED
HEREON IS THE EXCLUSIVE PROPERTY OF GROVE
CONCRETE & SUPPLY, INC., AND SHALL NOT BE
REPRODUCED, USED, OR DISCLOSED TO OTHERS
EXCEPT AS AUTHORIZED THROUGH WRITTEN CONCENT
FROM GROVE CONCRETE & SUPPLY, INC.