



GROVE CONCRETE & SUPPLY, INC.  
 18426 DURAND AVENUE P.O. BOX 383  
 UNION GROVE, WISCONSIN 53182  
 (262) 878-2030 FAX (262) 878-4222  
 GroveConcrete.com

**NOTES:**

1. GALLONS PER INCH:  
 1,000 COMPARTMENT - 17.74 gal/in.  
 450 COMPARTMENT - 8.06 gal/in.
2. REINFORCED CONCRETE 4,000 PSI MIN.
3. (GASKETED 4" OR 6" OPENING)  
 PRESS SEAL, TUFF TITE OR EQUAL.
4. (LABEL APPLIED TO COVER), WHEN  
 USED AS A GREASE INTERCEPTOR.
5. 5" MAX DEPTH OF COVER, 8" BURIAL  
 DEPTH WITH HEAVY DUTY COVER.
6. ALL BAFFLES & FILTERS TO BE  
 INSTALLED TO MEET STATE &  
 LOCAL CODES.
7. THIS TANK IS BUILT IN COMPLIANCE  
 OF SECT. 905.40 IL. PRIVATE SEWAGE  
 CODE.

(1,000 / 450 / 1,000) 2,450 3C  
 GALLON PUMP, SEPTIC, HOLDING TANK,  
 GREASE INTERCEPTOR

FOR ANY MODIFICATIONS CALL  
 GROVE CONCRETE

APPROVED BY:

DRAWN BY: RAY DATE: 3/4/15

SCALE: NTS EST. WEIGHT: 23,830 LBS. VERSION: 00002

DWG. # TNK-2450-3C-VER2 ILL. APPROVAL # 114

THIS DRAWING AND THE INFORMATION CONTAINED  
 HEREON IS THE EXCLUSIVE PROPERTY OF GROVE  
 CONCRETE & SUPPLY, INC., AND SHALL NOT BE  
 REPRODUCED, USED, OR DISCLOSED TO OTHERS  
 EXCEPT AS AUTHORIZED THROUGH WRITTEN CONCENT  
 FROM GROVE CONCRETE & SUPPLY, INC.

