



GROVE CONCRETE & SUPPLY, INC.
 18426 DURAND AVENUE P.O. BOX 363
 UNION GROVE, WISCONSIN 53182
 (262) 878-2030 FAX (262) 878-4222
 GroveConcrete.com

- NOTES:**
1. GALLONS PER INCH:
2,600 COMPARTMENT - 46.30 gal/in.
 2. REINFORCED CONCRETE 4,000 PSI MIN.
 3. (GASKETED 4" OR 6" OPENING)
PRESS SEAL, TUFF TITE OR EQUAL.
 4. (LABEL APPLIED TO COVER), WHEN
USED AS A GREASE INTERCEPTOR.
 5. 5' MAX DEPTH OF COVER, 8' BURIAL
DEPTH WITH HEAVY DUTY COVER.
 6. ALL BAFFLES & FILTERS TO BE
INSTALLED TO MEET STATE &
LOCAL CODES.
 7. THIS TANK IS BUILT IN COMPLIANCE
OF SECT. 905.40 IL. PRIVATE SEWAGE
CODE.

3054 - HOLDING / PUMP ONLY THROUGH TANK TOP		
2,850 - HOLDING / PUMP		
2600 - SEPTIC / PUMP GREASE INTERCEPTOR		
FOR ANY MODIFICATIONS CALL GROVE CONCRETE		
APPROVED BY:		
DRAWN BY: RAY	DATE: 2/19/15	
SCALE: NTS	EST. WIEGHT: 20,450 LBS.	VERSION: 00002
DWG. # TNK-2600-ver2	ILL. APPROVAL # 114	
THIS DRAWING AND THE INFORMATION CONTAINED HEREON IS THE EXCLUSIVE PROPERTY OF GROVE CONCRETE & SUPPLY, INC., AND SHALL NOT BE REPRODUCED, USED, OR DISCLOSED TO OTHERS EXCEPT AS AUTHORIZED THROUGH WRITTEN CONCENT FROM GROVE CONCRETE & SUPPLY, INC.		