

Red Gate Mobile Home Park

2024 Water Quality Report

Georgia Water System ID #: GA1030036

Name of Water System Contact (Phone Number):

Kristy Smith (912-237-4167)

Summary of Water Quality Information

The **Red Gate Mobile Home Park (MHP)** drinking water system is owned by the W. Neil Smith Estate and operated by **Tindall Enterprises, Inc.** The facility office address is located at 1239 River Street, NE, Townsend, Georgia. If there are ever any comments or inquiries to be made, please feel free to contact Kristy Smith at the number listed above.

Included in this report is information about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. **Red Gate Mobile Home Park** is committed to providing clean, safe, and reliable drinking water for everyone in the community. For more information about your water or this report please call **Tindall Enterprises, Inc.**, at 912-449-0999. **This report is available upon request at the facility office.**

Your water comes from well 101, a community *groundwater* well. This well is in **Red Gate Mobile Home Park** at 207 Wisenbaker Road in Rincon, Georgia and derives water from the *Coastal Plains Aquifer*. The well property is protected from activities which could potentially cause contamination of the well or water source. Any necessary treatment, such as removal of contaminants and/or addition of disinfectant is performed at the well site.

A **Source Water Assessment Plan** has been completed for this facility by the Georgia Department of Natural Resources Environmental Protection Division (GA EPD). It is a report that identifies any types of pollution to which your water supply could be vulnerable and includes information regarding potential sources of contamination in your watershed. This system is considered to be in the high susceptibility range for pollution. Utility poles are the only cited potential pollution sources present in the 15-foot control zone. Cited potential pollution sources in the 295-ft management zone are utility poles, access- and secondary roads, electrical transformers, non-domestic septic system, dumpsters, vehicle parking areas, as well as stormwater run-off potentially containing volatile organic compounds from parking areas and/or pesticides and herbicides from lawns. **This report is available upon request at the facility office.**

The **Red Gate Mobile Home Park** water system is tested for more than eighty (80) drinking water parameters on a periodic basis as determined by the GA EPD Drinking Water Program and/or the U.S Environmental Protection Agency. Sample/testing schedules are based on initial contaminant level assessments and can be changed if deemed necessary. Waivers may also be issued for the analysis of certain compounds if analytical data shows that the distributed drinking water in this area is not vulnerable to contamination from these chemicals.

Generally, samples are collected in **Red Gate Mobile Home Park** for analysis of lead, copper, inorganic-, volatile organic-, and synthetic organic compounds, once in a three (3) year cycle. The system is also monitored annually for nitrate-nitrites and monthly for the presence of bacteriological content. Radionuclide testing is performed every nine (9) years.

During 2024, the **Red Gate MHP** water system was sampled for the analysis of bacteriological content, inorganic compounds, volatile organic compounds, and nitrate-nitrites. **We are pleased to inform you that Red Gate Mobile Home Park did not have any violations of water quality parameters during 2024. All detected contaminants are delineated in the accompanying chart. Any contaminants not listed in the accompanying chart had results less than the detection limits.**

For the 2022 lead and copper monitoring event, five (5) representative locations were sampled for the analyses. **NO** sampled site exceeded the *Action Level*, however; detectable levels of copper were found in one or more sample(s). This may indicate the presence of this contaminant in some service lines or home plumbing. To access all individual lead tap sample results for **Red Gate MHP** visit www.gadrinkingwater.net.

The Service Line Inventory (SLI) is a requirement under the Lead and Copper Rule Revisions (LCRR) to help water systems identify and replace lead service lines. It mandates that all public water systems develop and maintain an inventory of service line materials to assess the presence of lead and protect public health. The inventory will support proactive lead reduction efforts and ensure compliance with regulatory requirements to minimize lead exposure in drinking water. **Due to an oversight, Red Gate MHP failed to submit the required lead service line inventory by the October 17, 2024, deadline, however, it has since been submitted to the proper authority and is available online at <https://ga-epd.120water-ptd.com/>.**

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Red Gate MHP is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time.

*You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact **Red Gate MHP**. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.*

Additionally, the following measures may also be taken to minimize exposure to lead and/or copper:

- Use cold water for drinking or cooking.
- Do not cook with or consume water from the hot water faucet.
- Do not use hot water for making baby formula.
- Use only “lead-free” solder, fluxes and materials in new household plumbing and repairs.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. **More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline at 800-426-4791.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. **EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include the following:

- **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants** such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the number of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Red Gate Mobile Home Park strives to maintain the highest standards of performance and quality possible. In order to maintain a safe and dependable water supply, improvements that benefit the community must be made. Please help keep these costs as low as possible by utilizing good water conservation practices.

DEFINITION OF TERMS AND ABBREVIATIONS USED IN THIS REPORT

Maximum Residual Disinfectant Level (MRDL): “The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants.”

Maximum Residual Disinfectant Level Goal (MRDLG): “The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TTHMs (Total Trihalomethanes): One or more of the organic compounds Chloroform, Bromodichloromethane, Chlorodibromomethane, and/or Bromoform.

HAA5s (Haloacetic Acids): One or more of the organic compounds Monochloroacetic Acid, Dichloroacetic Acid, Trichloroacetic Acid, Monobromoacetic Acid, and Dibromoacetic Acid.

Red Gate Mobile Home Park
2024 Water Quality Data
WSID: GA1030036

The table below lists all the drinking water contaminants that have been detected in your drinking water. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The data presented in this table is from testing done during the year noted. The Federal Environmental Protection Agency (EPA) and the Georgia Department of Natural Resources Environmental Protection Division (EPD) require monitoring for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Parameters, values, and/or sources may vary.

DETECTED INORGANIC CONTAMINANTS TABLE								
Parameter	Units	MCL [SMCL]	MCLG	Red Gate MHP Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Fluoride	ppm	4 [2]	4	0.49	0.49 to 0.49	2024	No	Erosion of natural deposits; water additive

OTHER DETECTED UNREGULATED CONTAMINANTS TABLE								
Parameter	Units	MCL [SMCL]	MCLG	Red Gate MHP Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Sodium	ppm	**	**	15.0	15.0 to 15.0	2024	No	Erosion of natural deposits

LEAD AND COPPER MONITORING RESULTS								
Parameter	Units	Action Level	MCLG	Red Gate MHP 90th Percentile	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Lead	ppb	15	0	ND	N/A	2022	No	Corrosion of household plumbing
Copper	ppm	1.3	1.3	0.004	ND to 0.0037	2022	No	Corrosion of household plumbing

MICROBIOLOGICAL MONITORING RESULTS								
Parameter	Units	MCL	MCLG	Red Gate MHP # of Positive Samples	Positive Sample Date (Month/Year)	Sample Year	Violation No/Yes	Typical Source of Contaminant
Total Coliform	Present/	1*	0	0	N/A	2024	No	Naturally present in the environment
E. coli	Absent	0	0	0	N/A	2024	No	Human and animal fecal waste

RADIONUCLIDES TABLE								
Parameter	Units	MCL	MCLG	Red Gate MHP Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Alpha emitters	pCi/L	15	0	ND	N/A	2020	No	Erosion of natural deposits
Combined Radium 226/228	pCi/L	5	0	ND	N/A	2020	No	Erosion of natural deposits

- *Total Coliform Rule MCL= 1 positive sample for systems that collect <40 samples a month ** No established MCL, SMCL or MCLG
- N/A: Not applicable to this contaminant •ppb (ug/L): parts per billion or micrograms per liter •ppm (mg/L): parts per million or milligrams per liter •pCi/l: picocuries per liter, a measurement of radiation
- ND (Not Detected): By regulation, this substance or group of substances was tested for in our finished tap water; however, none was detected at the testing limit.
- Action Level (AL): "The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow."
- Maximum Contaminant Level (MCL): "The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG as feasible using the best available treatment technology."
- Maximum Contaminant Level Goal (MCLG): "The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety."
- Secondary Maximum Contaminant Level (SMCL): Reasonable goals for drinking water quality. Exceeding SMCL's may adversely affect odor or appearance, but there is no known risk to human health.