



NOTES:

1. VANDAL ENCLOSURE TO BE "QEM 1 GUARDSHACK" OR EPCOR WATER APPROVED EQUAL.
2. COPPER LINE FROM MAIN TO AIR RELEASE VALVE TO BE INSTALLED WITH POSITIVE SLOPE TO PREVENT BLOCKAGE.
3. PROVIDE PER EPCOR WATER SPECIFICATIONS APPROVED MATERIALS LIST.
4. MAG STANDARD 140-1 PROTECTION BOLLARDS IN TRAFFIC AREAS.
5. ALL ABOVE GROUND AIR RELEASE VALVES MUST BE PRE-APPROVED BY EPCOR WATER. UNDERGROUND AIR RELEASE VALVES PER EPCOR WATER'S STD. DET. 351-3.

DATE: JAN '15	EPCOR WATER	2355 W Pinnacle Peak Rd, Ste 300 Phoenix, AZ 85027 P 623.445.2400 F 623.587.1044	POTABLE AIR RELEASE VALVE	DETAIL NO. 351-1
-------------------------	--------------------	--	----------------------------------	----------------------------