





Quality ACCA Manual J load calculations &
Manual D duct designs since 2005

Report SEG 0314-077W / March 2014

Right-Sized Residence

Manual J Street, Oak Park, IL 60301

Prepared by: Tracy Savoy



DISCLAIMER

The following pages summarize the heat gain and heat loss of the building using the ACCA Manual J8 calculation procedure. The calculations are based on the information given to Savoy Engineering Group in the form of drawings, sketches, and interviews. In certain cases, Savoy Engineering Group may make assumptions about design conditions that may or may not be accurate for the location of concern. It is the responsibility of the installing HVAC contractor to verify the design conditions **before** equipment purchase and installation.

Any load calculations provided in the following pages are based upon information provided by the party submitting a particular project to Savoy Engineering Group. Savoy Engineering Group has not and does not independently verify that the data provided to Savoy Engineering Group is correct or complete, and any calculations made by Savoy Engineering Group are based upon the information provided by third parties. Savoy Engineering Group makes no claim that the information given to us is correct or complete.

Savoy Engineering Group utilizes WrightSoft Residential 13.0 which is an ACCA Certified and ASHRAE recommended computer program to determine the heating and cooling loads presented in this report, and is therefore very accurate. If the information given to Savoy Engineering Group is accurate, and the building is built as per the plans submitted, then the load calculations presented in this report can be assumed to be accurate. A licensed mechanical contractor may use these calculations as a starting point in system sizing and selection.

Savoy Engineering Group does not provide architectural or engineering plans or diagrams for the public or for use by contractors or construction companies as final “construction documents”. Savoy Engineering Group works with architectural and engineering firms and with contractors in connection with their designs of heating and air conditioning systems.

If the HVAC duct layout installed on-site DOES NOT match the Manual D duct design prepared by Savoy Engineering Group, then Savoy Engineering Group cannot and will not guarantee the performance of any altered duct design.


Final HVAC sizing and selection should be done by a licensed HVAC contractor. Many factors beyond the scope of this report must be considered prior to final system selection and design, such as: exact equipment availability and selections, system controls and location of controls, system air distribution and cycling, Uniform Building Code requirements, Uniform Mechanical Code requirements, and many other standard design conventions as listed by the American Society of Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE).


Savoy Engineering Group therefore assumes no liability for final equipment selection or final system design. Various modifications to the information provided to Savoy Engineering Group may have occurred after this Design Support information was prepared, which would require that this Design Support information be modified in order to be accurate. After reviewing Savoy Engineering Group's report, and prior to any system purchase or installation, please inform Savoy Engineering Group in writing of any changes which may alter the assumptions and calculations contained in this report.

Elevation: 620 feet

Average climate in Oak Park, Illinois

Based on data reported by over 4,000 weather stations





<http://www.city-data.com/city/Oak-Park-Illinois.html>

SUMMARY

ACCA Certified Manual J Load Calculation – Design Data Summary

Mode	Total Load BTUh	Sensible Load BTUh	Latent Load BTUh	A/C Cooling Tons	Design Outdoor Conditions	Indoor Conditions
Entire House						
Heating	42,397	N/A	N/A	N/A	4 °F	70 °F
Cooling	21,064	16,454	4,609	1.8	90 °F	75 °F, 50% RH

The ACCA Certified Load Analysis includes:

- SHR of 0.78 (Sensible/Total)
- The Load Analysis includes people 4 (# of Bedrooms + 1) and a 1,200 BTUh appliance load
- The Load Analysis includes a duct loss:
 - OPEN UNCONDITIONED CRAWLSPACE duct location

Per Energy Star:

- AC cooling equipment should be sized at 95-115% of Design Total Heat Gain, or the next nominal size that is available to satisfy the latent and sensible requirements.
- Heat pump cooling equipment should be sized at 100-115% (cooling dominant climate) or 100-125% (heating dominant climate) of Design Total Heat Gain, or the next nominal size that is available to satisfy the latent and sensible requirements unless a larger size is dictated by the heating equipment selection.
- Listed Output Heat Capacity must be sized at 100-140% of Design Total Heat Loss, or next nominal size unless a larger size is dictated by the cooling equipment selection.

Project Information

For: Right-Sized Residence
ACCA Manual J Street, Oak Park, IL 60301

Design Conditions

Location:

Chicago Midway AP, IL, US
Elevation: 617 ft
Latitude: 42°N

Outdoor:

	Heating	Cooling
Dry bulb (°F)	4	90
Daily range (°F)	-	16 (L)
Wet bulb (°F)	-	73
Wind speed (mph)	15.0	7.5

Indoor:


Indoor temperature (°F)	70	75
Design TD (°F)	66	15
Relative humidity (%)	30	50
Moisture difference (gr/lb)	27.8	34.1

Infiltration:

Method	Simplified
Construction quality	Average
Fireplaces	2 (Average)


Heating

Component	Btuh/ft ²	Btuh	% of load
Walls	4.3	6033	14.2
Glazing	23.0	5735	13.5
Doors	17.1	359	0.8
Ceilings	1.7	3310	7.8
Floors	1.9	3632	8.6
Infiltration	5.8	9719	22.9
Ducts		11276	26.6
Piping		0	0
Humidification		0	0
Ventilation		2335	5.5
Adjustments		0	0
Total		42397	100.0



Cooling

Component	Btuh/ft ²	Btuh	% of load
Walls	0.8	1125	6.8
Glazing	20.4	5080	30.9
Doors	7.3	154	0.9
Ceilings	1.1	2098	12.8
Floors	0.4	807	4.9
Infiltration	0.5	914	5.6
Ducts		3638	22.1
Ventilation		519	3.2
Internal gains		2120	12.9
Blower		0	0
Adjustments		0	0
Total		16454	100.0



Latent Cooling Load = 4609 Btuh
Overall U-value = 0.054 Btuh/ft²-°F

Data entries checked.

Phone: (801) 949-5337 Web: www.load-calculations.com

Project Information

For: Right-Sized Residence
 ACCA Manual J Street, Oak Park, IL 60301

Design Conditions

Location:

 Chicago Midway AP, IL, US
 Elevation: 617 ft
 Latitude: 42°N

	Indoor:	Heating	Cooling
	Indoor temperature (°F)	70	75
	Design TD (°F)	66	15
	Relative humidity (%)	30	50
	Moisture difference (gr/lb)	27.8	34.1


Outdoor:

	Heating	Cooling
Dry bulb (°F)	4	90
Daily range (°F)	-	16 (L)
Wet bulb (°F)	-	73
Wind speed (mph)	15.0	7.5

Infiltration:

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 20.3%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh



Component Constructions

Entire House

Savoy Engineering Group

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

Project Information

For: Right-Sized Residence
ACCA Manual J Street, Oak Park, IL 60301

Design Conditions

Location:	Indoor:	Heating	Cooling
Chicago Midway AP, IL, US	Indoor temperature (°F)	70	75
Elevation: 617 ft	Design TD (°F)	66	15
Latitude: 42°N	Relative humidity (%)	30	50
	Moisture difference (gr/lb)	27.8	34.1
Outdoor:	Infiltration:		
Dry bulb (°F)	Method		
Daily range (°F)	Construction quality		
Wet bulb (°F)	Fireplaces		
Wind speed (mph)			
15.0			
	Simplified		
	Average		
	2 (Average)		

Construction descriptions	Or	Area ft ²	U-value Btu/h/ft ² °F	Insul R ft ² °F/Btu/h	Htg HTM Btu/h/ft ²	Loss Btu/h	Cig HTM Btu/h/ft ²	Gain Btu/h
Walls								
12F-Obw: Frm wall, brk 4" ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int fnsh, 2"x6" wood frm	n	472	0.065	21.0	4.27	2014	0.80	376
	e	234	0.065	21.0	4.27	999	0.80	186
	s	467	0.065	21.0	4.27	1996	0.80	372
	w	240	0.065	21.0	4.27	1023	0.80	191
	all	1413	0.065	21.0	4.27	6033	0.80	1125
Partitions								
(none)								
Windows								
10D-c: 2 glazing, clr low-e outr, air gas, clad wd frm mat, clr innr, 1/4" gap, 1/8" thk; NFRC rated (SHGC=0.31)	n	54	0.350	0	23.0	1251	7.73	421
	n	37	0.350	0	23.0	839	11.0	403
	e	45	0.350	0	23.0	1035	34.2	1541
	s	74	0.350	0	23.0	1705	18.5	1369
	w	39	0.350	0	23.0	904	34.2	1347
	all	249	0.350	0	23.0	5735	20.4	5080
Doors								
11E0: Door, wd sc type, wd strm	s	21	0.260	0	17.1	359	7.32	154
Ceilings								
16C-38aw: Attic ceiling, asphalt shingles roof mat, r-38 ceil ins, 1/2" gypsum board int fnsh		1938	0.026	38.0	1.71	3310	1.08	2098
Floors								
19A-30bstp: Flr floor, frm flr, 10" thkns, r-30 cav ins, tight bsmt ovr		1938	0.034	30.0	1.87	3632	0.42	807



Load Short Form
Entire House
Savoy Engineering Group

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

Project Information

For: Right-Sized Residence
ACCA Manual J Street, Oak Park, IL 60301

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	4	90	Method	Simplified
Inside db (°F)	70	75	Construction quality	Average
Design TD (°F)	66	15	Fireplaces	2 (Average)
Daily range	-	L		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	28	34		

HEATING EQUIPMENT

Make	Goodman Mfg.
Trade	GOODMAN
Model	GCH950453BX**
AHRI ref	3653909
Efficiency	95 AFUE
Heating input	46000 Btuh
Heating output	44000 Btuh
Temperature rise	51 °F
Actual air flow	800 cfm
Air flow factor	0.020 cfm/Btuh
Static pressure	0.60 in H2O
Space thermostat	

COOLING EQUIPMENT

Make	Goodman Mfg.
Trade	GOODMAN
Cond	SSX160241B*
Coil	CA*F3636*6D*
AHRI ref	4652177
Efficiency	13.2 EER, 16 SEER
Sensible cooling	18720 Btuh
Latent cooling	5280 Btuh
Total cooling	24000 Btuh
Actual air flow	800 cfm
Air flow factor	0.050 cfm/Btuh
Static pressure	0.60 in H2O
Load sensible heat ratio	0.78

ROOM NAME	Area (ft ²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Master Bedroom	240	7575	2618	151	131
Master Bath	112	2734	590	55	30
Master Wic	98	0	0	0	0
Den	150	2507	644	50	32
Dining	129	2095	506	42	25
Kitchen	176	4861	3265	97	164
Living Room	394	9296	4527	186	227
CL 2	34	0	0	0	0
Bedroom 2	192	5733	2242	114	113
Hall	126	0	0	0	0
Bath 2	90	1481	312	30	16
Bedroom 3	198	3780	1232	75	62

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Entire House	d	1939	40063	15935	800	800
Other equip loads			2335	519		
Equip. @ 1.00 RSM				16454		
Latent cooling				4609		
TOTALS		1939	42397	21064	800	800

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-J® Worksheet Entire House Savoy Engineering Group

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1	Room name Exposed wall Room height Room dimensions Room area				Entire House 9.0 ft 187.0 ft d 1938.9 ft ²				Master Bedroom 9.0 ft 31.0 ft heat/cool 16.0 x 15.0 ft 240.0 ft ²				
Ty	Construction number	U-value (Btuh/ft ² °F)	Or	HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)	
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	563 54 37	472 0 0	2014 1251 839	376 421 403	144 54 0	90 0 0	383 1251 421	71 0 0
11	W G 4A5-2oc	0.065 0.350 0.350	e e e	4.27 22.99 22.99	0.80 34.24 34.24	279 45 45	234 0 0	999 1035 1035	186 1541 1541	0 0 0	0 0 0	0 0 0	0 0 0
11	W G 4A5-2oc D 11E0	0.065 0.350 0.350 0.260	s s s s	4.27 22.99 22.99 17.08	0.80 18.46 18.46 7.32	563 74 74 21	467 0 0 21	1996 1705 1705 359	372 1369 1369 154	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0
W	12F-0bw 4A5-2oc	0.065 0.350	w w	4.27 22.99	0.80 34.24	279 39	240 0	1023 904	191 1347	135 20	115 0	493 452	92 673
C	16C-38aw	0.026	-	1.71	1.08	1938	1938	3310	2098	240	240	410	260
F	19A-30bstp	0.034	-	1.87	0.42	1938	1938	3632	807	240	240	450	100
6	c) AED excursion							0					144
	Envelope loss/gain							19068	9264			3438	1761
12	a) Infiltration b) Room ventilation							9719 0	914 0			1611 0	151 0
13	Internal gains: Occupants @ 230 Appliances/other			4				920 1200	0			0 0	0 0
	Subtotal (lines 6 to 13)							28787	12298			5049	1912
14	Less external load Less transfer Redistribution Subtotal Duct loads							0 0 0 28787 11276	0 0 0 12298 3638			0 0 393 5443 2132	0 0 108 2020 598
15	Total room load Air required (cfm)							40063 800	15935 800			7575 151	2618 131

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J® Worksheet
Entire House
Savoy Engineering Group**

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1	Room name Exposed wall Room height Room dimensions Room area				Master Bath 14.0 ft 9.0 ft 14.0 x 8.0 ft 112.0 ft ²				Master Wic 0 ft 9.0 ft 14.0 x 7.0 ft 98.0 ft ²				
Ty	Construction number	U-value (Btuh/ft ² °F)	Or	HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)	
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	126 0 7	120 0 0	510 0 149	95 0 72	0 0 0	0 0 0	0 0 0	0 0 0
11	W G 4A5-2oc	0.065 0.350	e e	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
.	W G 4A5-2oc	0.065 0.350	s s	4.27 22.99	0.80 18.46	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
.	W G D 11E0	0.065 0.350 0.260	s s s	4.27 22.99 17.08	0.80 34.24 7.32	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
.	W G 4A5-2oc	0.065 0.350	w w	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
C	16C-38aw	0.026	-	1.71	1.08	112	112	191	121	98	98	167	106
F	19A-30bstp	0.034	-	1.87	0.42	112	112	210	47	98	98	184	41
6	c) AED excursion								-18				-7
	Envelope loss/gain							1061	317			351	140
12	a) Infiltration b) Room ventilation							728 0	68 0			0 0	0 0
13	Internal gains: Occupants @ 230 Appliances/other			0				0 0	0 0			0 0	0 0
	Subtotal (lines 6 to 13)							1789	385			351	140
14	Less external load Less transfer Redistribution Subtotal Duct loads					0 0 176 1964 769	0 0 70 455 135					0 0 -351 0 0	0 0 -140 0 0
15	Total room load Air required (cfm)			39%	30%	2734 55	590 30					0 0	0 0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J® Worksheet
Entire House
Savoy Engineering Group**

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1 2 3 4 5					Den				Dining				
					9.0 ft	10.0 ft	heat/cool	9.0 ft	9.5 ft	heat/cool			
Ty	Construction number	U-value (Btu/h/ft ² °F)	Or	HTM (Btu/h/ft ²)		Area (ft ²) or perimeter (ft)	Load (Btu/h)	Area (ft ²) or perimeter (ft)		Load (Btu/h)			
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	90 0 10	80 0 0	342 0 230	64 0 110	86 0 10	76 0 0	322 0 230	60 0 110
11	W G 4A5-2oc	0.065 0.350	e e	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
	W G 4A5-2oc	0.065 0.350	s s	4.27 22.99	0.80 18.46	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
	W G 11E0	0.260	s	17.08	7.32	0	0	0	0	0	0	0	0
	W G 4A5-2oc	0.065 0.350	w w	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
	C F 16C-38aw 19A-30bstp	0.026 0.034	- -	1.71 1.87	1.08 0.42	150 150	150 150	256 281	162 62	128 128	128 128	219 240	139 53
6	c) AED excursion								-20				-19
	Envelope loss/gain							1109	379			1012	344
12	a) Infiltration b) Room ventilation							520 0	49 0			494 0	46 0
13	Internal gains: Occupants @ 230 Appliances/other			0				0 0	0 0			0 0	0 0
	Subtotal (lines 6 to 13)							1629	428			1506	391
14	Less external load Less transfer Redistribution Subtotal							0 0 173 1802	0 0 69 497			0 0 0 1506	0 0 0 391
15	Duct loads			39%	30%	706	706	147	39%	30%	590	590	116
	Total room load Air required (cfm)							2507 50	644 32			2095 42	506 25

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J® Worksheet
Entire House
Savoy Engineering Group**

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1	Room name Exposed wall Room height Room dimensions Room area				Kitchen 26.5 ft 9.0 ft heat/cool 13.0 x 13.6 ft 176.3 ft ²				Living Room 40.0 ft heat/cool 22.5 x 17.5 ft 393.8 ft ²				
Ty	Construction number	U-value (Btuh/ft ² °F)	Or	HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)	
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	117 0 10	107 0 0	457 0 230	85 0 110	0 0 0	0 0 0	0 0 0	0 0 0
11	W G 4A5-2oc	0.065 0.350	e e	4.27 22.99	0.80 34.24	122 15	107 0	455 345	85 514	158 30	128 0	544 690	102 1027
	W G 4A5-2oc	0.065 0.350	s s	4.27 22.99	0.80 18.46	0 0	0 0	0 0	0 0	203 42	139 0	595 968	111 777
	W D 11E0	0.065 0.260	w s	4.27 17.08	0.80 7.32	0 0	0 0	0 0	0 0	21 21	21 21	359 359	154 154
	W G 4A5-2oc	0.065 0.350	w w	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
	C F 16C-38aw 19A-30bstp	0.026 0.034	- -	1.71 1.87	1.08 0.42	176 176	176 176	300 329	190 73	394 394	394 394	673 738	426 164
6	c) AED excursion								-97				-166
	Envelope loss/gain							2115	961			4567	2595
12	a) b)	Infiltration Room ventilation						1377 0	129 0			2079 0	195 0
13	Internal gains: Occupants @ 230 Appliances/other				1			230 1200	3			690 0	
	Subtotal (lines 6 to 13)							3493	2520			6646	3480
14	Less external load Less transfer Redistribution Subtotal							0 0 0	0 0 0			0 0 34	0 0 14
15	Duct loads				39%	30%	3493 1368	2520 745	39%	30%	6680 2617	3494 1033	
	Total room load Air required (cfm)						4861 97	3265 164			9296 186	4527 227	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J® Worksheet
Entire House
Savoy Engineering Group**

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1	Room name Exposed wall Room height Room dimensions Room area				CL 2 4.0 ft 9.0 ft 8.5 x 4.0 ft heat/cool 34.0 ft ²				Bedroom 2 28.0 ft 9.0 ft 16.0 x 12.0 ft heat/cool 192.0 ft ²				
Ty	Construction number	U-value (Btu/h/ft ² °F)	Or	HTM (Btu/h/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btu/h)		Area (ft ²) or perimeter (ft)		Load (Btu/h)	
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
11	W G 4A5-2oc	0.065 0.350 0.350	e e e	4.27 22.99 22.99	0.80 34.24 34.24	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
.	W G 4A5-2oc	0.065 0.350 0.350	s s s	4.27 22.99 22.99	0.80 18.46 34.24	0 0 0	0 0 0	0 0 0	0 0 0	144 12 0	132 12 0	563 278 223	105 0 0
.	W G D 11E0	0.065 0.350 0.260	w s s	4.27 22.99 17.08	0.80 34.24 7.32	36 0 0	36 0 0	154 0 0	29 0 0	108 20 0	88 20 0	377 452 0	70 673 0
.	W G 4A5-2oc	0.065 0.350 0.350	w w w	4.27 22.99 22.99	0.80 34.24 34.24	34 0 0	34 0 0	58 0 0	37 0 0	192 192 192	192 192 192	328 452 360	208 673 80
.	C F 16C-38aw 19A-30bstp	0.026 0.034	- -	1.71 1.87	1.08 0.42	34 34	34 34	64 14	37 14				
6	c) AED excursion									-5			161
	Envelope loss/gain							276	75			2359	1521
12	a) Infiltration b) Room ventilation							208 0	20 0			1455 0	137 0
13	Internal gains: Occupants @ 230 Appliances/other			0				0 0	0 0			0 0	0 0
	Subtotal (lines 6 to 13)							483	95			3814	1657
14	Less external load Less transfer Redistribution Subtotal Duct loads					0 0 -483 0	0 0 -95 0					0 0 306 4119	0 0 73 1730
15	Total room load Air required (cfm)			39%	30%	0 0	0 0	39% 30%	30% 30%			5733 114	2242 113

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J® Worksheet
Entire House
Savoy Engineering Group**

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1 2 3 4 5	Room name Exposed wall Room height Room dimensions Room area				Hall 0 ft 9.0 ft heat/cool 31.5 x 4.0 ft 126.0 ft ²				Bath 2 7.5 ft 9.0 ft heat/cool 7.5 x 12.0 ft 90.0 ft ²					
					HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)	
Ty	Construction number	U-value (Btuh/ft ² °F)	Or	Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
11	W G 4A5-2oc	0.065 0.350 0.350	e e e	4.27 22.99 22.99	0.80 34.24 34.24	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
	W G 4A5-2oc	0.065 0.350 0.350	s s s	4.27 22.99 17.08	0.80 18.46 7.32	0 0 0	0 0 0	0 0 0	0 0 0	68 0 0	68 0 0	288 0 0	54 0 0	
	W G 11E0	0.065 0.350 0.260	w w s	4.27 22.99 22.99	0.80 34.24 34.24	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
	W G 4A5-2oc	0.065 0.350 0.350	w w w	4.27 22.99 22.99	0.80 34.24 34.24	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
	C F 16C-38aw 19A-30bstp	0.026 0.034 0.034	- - -	1.71 1.87 1.87	1.08 0.42 0.42	126 126 126	126 126 236	215 236 52	136 90 90	90 90 90	90 90 90	154 169 169	97 37 37	
6	c) AED excursion									-9				-10
	Envelope loss/gain							451	180			611	178	
12	a) Infiltration b) Room ventilation							0 0	0 0			390 0	37 0	
13	Internal gains: Occupants @ 230 Appliances/other			0				0 0	0 0			0 0	0 0	
	Subtotal (lines 6 to 13)							451	180			1001	215	
14	Less external load Less transfer Redistribution Subtotal Duct loads					0 0 -451 0	0 0 -180 0					0 0 64 1064	0 0 26 417	
15	Total room load Air required (cfm)			39%	30%	0 0	0 0	39% 30%	30% 30%			1481 30	312 16	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J® Worksheet
Entire House
Savoy Engineering Group**

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

1	Room name Exposed wall Room height Room dimensions Room area				Bedroom 3 16.5 ft 9.0 ft heat/cool 16.5 x 12.0 ft 198.0 ft ²								
Ty	Construction number	U-value (Btu/h/ft ² °F)	Or	HTM (Btu/h/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btu/h)		Area or perimeter		Load	
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W G G 4A5-2oc	0.065 0.350 0.350	n n n	4.27 22.99 22.99	0.80 7.73 11.05	0 0 0	0 0 0	0 0 0	0 0 0				
11	W G 4A5-2oc	0.065 0.350	e e	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0				
.	W G 4A5-2oc	0.065 0.350	s s	4.27 22.99	0.80 18.46	149 20	129 0	549 460	102 369				
.	W G D 11E0	0.065 0.350 0.260	s s s	4.27 22.99 17.08	0.80 34.24 7.32	0 0 0	0 0 0	0 0 0	0 0 0				
.	W G 4A5-2oc	0.065 0.350	w w	4.27 22.99	0.80 34.24	0 0	0 0	0 0	0 0				
C	16C-38aw	0.026	-	1.71	1.08	198	198	338	214				
F	19A-30bstp	0.034	-	1.87	0.42	198	198	371	82				
6	c) AED excursion									45			
	Envelope loss/gain							1718	814				
12	a) Infiltration b) Room ventilation							858 0	81 0				
13	Internal gains: Occupants @ 230 Appliances/other			0					0				
	Subtotal (lines 6 to 13)							2576	895				
14	Less external load Less transfer Redistribution Subtotal Duct loads							0 0 141 2716 1064	0 0 56 951 281				
15	Total room load Air required (cfm)							3780 75	1232 62				

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Project Summary

Entire House

Savoy Engineering Group

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

Project Information

For: Right-Sized Residence
ACCA Manual J Street, Oak Park, IL 60301

Notes: Joe Contractor
Superior HVAC

Design Information

Weather: Chicago Midway AP, IL, US

Winter Design Conditions

Outside db	4 °F
Inside db	70 °F
Design TD	66 °F

Summer Design Conditions

Outside db	90 °F
Inside db	75 °F
Design TD	15 °F
Daily range	L
Relative humidity	50 %
Moisture difference	34 gr/lb

Heating Summary

Structure	28787 Btuh
Ducts	11276 Btuh
Central vent (33 cfm)	2335 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	42397 Btuh

Infiltration

Method	Simplified	
Construction quality	Average	
Fireplaces	2 (Average)	
Area (ft ²)	Heating	Cooling
1939	1939	1939
Volume (ft ³)	17450	17450
Air changes/hour	0.47	0.20
Equiv. AVF (cfm)	138	58

Heating Equipment Summary

Make	Goodman Mfg.
Trade	GOODMAN
Model	GCH950453BX**
AHRI ref	3653909
Efficiency	95 AFUE
Heating input	46000 Btuh
Heating output	44000 Btuh
Temperature rise	51 °F
Actual air flow	800 cfm
Air flow factor	0.020 cfm/Btu
Static pressure	0.60 in H ₂ O
Space thermostat	

Sensible Cooling Equipment Load Sizing

Structure	12298 Btuh
Ducts	3638 Btuh
Central vent (33 cfm)	519 Btuh
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	16454 Btuh

Latent Cooling Equipment Load Sizing

Structure	2120 Btuh
Ducts	1740 Btuh
Central vent (33 cfm)	750 Btuh
Equipment latent load	4609 Btuh
Equipment total load	21064 Btuh
Req. total capacity at 0.78 SHR	1.8 ton

Cooling Equipment Summary

Make	Goodman Mfg.
Trade	GOODMAN
Cond	SSX160241B*
Coil	CA*F3636*6D*
AHRI ref	4652177
Efficiency	13.2 EER, 16 SEER
Sensible cooling	18720 Btuh
Latent cooling	5280 Btuh
Total cooling	24000 Btuh
Actual air flow	800 cfm
Air flow factor	0.050 cfm/Btu
Static pressure	0.60 in H ₂ O
Load sensible heat ratio	0.78

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2013 13.0.09 RSU13868

...e J, S and D report for website\Right-Sized.rup Calc = MJ8 Front Door faces: S

2014-Mar-18 18:55:54

Page 1



Manual S Compliance Report

Entire House

Savoy Engineering Group

Job: SEG 0314-077W
Date: Mar 17, 2014
By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

Project Information

For: Right-Sized Residence
ACCA Manual J Street, Oak Park, IL 60301

Cooling Equipment

Design Conditions

Outdoor design DB: 89.6°F	Sensible gain: 16454 Btuh	Entering coil DB: 77.0°F
Outdoor design WB: 73.3°F	Latent gain: 4609 Btuh	Entering coil WB: 64.1°F
Indoor design DB: 75.0°F	Total gain: 21064 Btuh	
Indoor RH: 50%	Estimated airflow: 800 cfm	

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split AC		
Manufacturer: Goodman Mfg.	Model: SSX160241B*+CA*F3636*6D*	
Actual airflow: 800 cfm		
Sensible capacity: 18121 Btu/h	110% of load	
Latent capacity: 4900 Btu/h	106% of load	
Total capacity: 23021 Btu/h	109% of load	SHR: 79%

Heating Equipment

Design Conditions

Outdoor design DB: 4.3°F	Heat loss: 42397 Btuh	Entering coil DB: 60.8°F
Indoor design DB: 70.0°F		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Gas furnace		
Manufacturer: Goodman Mfg.	Model: GCH950453BX**	
Actual airflow: 800 cfm		
Output capacity: 44000 Btu/h	104% of load	Temp. rise: 50 °F

The above equipment was selected in accordance with ACCA Manual S.



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1
15 Mar 09

Header Information

Contractor: Savoy Engineering Group

Mechanical license:

Building plan #:

Home address (Street or Lot#, Block, Subdivision): ACCA Manual J Street, Entire House

REQUIRED ATTACHMENTS

Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>

Manual J1 Form (and supporting worksheets):
or MJ1AE Form* (and supporting worksheets):
OEM performance data (heating, cooling, blower):
Manual D Friction Rate Worksheet:
Duct distribution sketch:

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature:	4 °F
Indoor temperature:	70 °F
Total heat loss:	42397 Btuh

Summer Design Conditions

Outdoor temperature:	90 °F
Indoor temperature:	75 °F
Grains difference:	34 gr/lb @ 50% RH
Sensible heat gain:	16454 Btuh
Latent heat gain:	4609 Btuh
Total heat gain:	21064 Btuh

Building Construction Information


Building

Orientation: Front Door faces South
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 3
Conditioned floor area: 1939 ft²
Number of occupants: 4

Windows

Eave overhang depth: 0 ft
Internal shade: none
Blinds, drapes, etc.
Number of skylights: 0



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type:
Furnace, Heat pump, Boiler, etc.

Gas furnace

Model: Goodman Mfg.
GCH950453BX**+

Heating output capacity:
Heat pumps - capacity at winter design outdoor conditions

Aux. heating output capacity: 0 Btuh

Cooling Equipment Data

Equipment type:
Air Conditioner, Heat pump, etc.

Split AC

Model: Goodman Mfg.
SSX160241B*+CA*F3636*6D*

Total cooling capacity: 23021 Btuh

Sensible cooling capacity: 18121 Btuh

Latent cooling capacity: 4900 Btuh

Blower Data

Heating cfm: 800
Cooling cfm: 800
Static pressure: 0.60 in H₂O
Fan's rated external static pressure for design airflow

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow:	800 cfm	Longest supply duct:	232 ft	Duct Materials Used
Equipment design ESP:	0.60 in H ₂ O	Longest return duct:	197 ft	Trunk duct:
Total device pressure losses:	-0.3 in H ₂ O	Total effective length (TEL):	429 ft	Sheet metal
Available static pressure (ASP):	0.33 in H ₂ O	Friction rate:	0.077 in/100ft <small>Friction Rate = ASP ÷ (TEL × 100)</small>	Branch duct: Round flex vinyl, Sheet metal

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name:

Contractor's signature:

Date:

Reserved for County, Town Municipality or Authority having jurisdiction use.

*Home qualifies for MJ1AE Form based on Abridged Edition Checklist



Duct System Summary

Entire House

Savoy Engineering Group

Job: SEG 0314-077W
 Date: Mar 17, 2014
 By: Tracy Savoy

Phone: (801) 949-5337 Web: www.load-calculations.com

Project Information

For: Right-Sized Residence
 ACCA Manual J Street, Oak Park, IL 60301

	Heating	Cooling
External static pressure	0.60 in H ₂ O	0.60 in H ₂ O
Pressure losses	0.27 in H ₂ O	0.27 in H ₂ O
Available static pressure	0.33 in H ₂ O	0.33 in H ₂ O
Supply / return available pressure	0.178 / 0.152 in H ₂ O	0.178 / 0.152 in H ₂ O
Lowest friction rate	0.077 in/100ft	0.077 in/100ft
Actual air flow	800 cfm	800 cfm
Total effective length (TEL)	429 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bath 2	h 1481	30	16	0.084	4.0	0x0	VIFx	21.3	190.0	st5
Bedroom 2	h 5733	114	113	0.115	7.0	0x0	VIFx	29.5	125.0	st4
Bedroom 3	h 3780	75	62	0.081	5.0	0x0	VIFx	29.5	190.0	st5
Den	h 2507	50	32	0.082	4.0	0x0	VIFx	33.5	185.0	st6
Dining	h 2095	42	25	0.080	6.0	0x0	VIFx	44.0	180.0	st7
Kitchen	c 1633	49	82	0.078	6.0	0x0	VIFx	54.5	175.0	st10
Kitchen-A	c 1633	49	82	0.077	6.0	0x0	VIFx	56.5	175.0	st10
Living Room	c 2264	93	114	0.087	7.0	0x0	VIFx	54.3	150.0	st11
Living Room-A	c 2264	93	114	0.088	7.0	0x0	VIFx	53.2	150.0	st11
Master Bath	h 2734	55	30	0.084	5.0	0x0	VIFx	22.0	190.0	st5
Master Bedroom	h 3787	76	66	0.107	5.0	0x0	VIFx	31.7	135.0	st2
Master Bedroom-A	h 3787	76	66	0.107	5.0	0x0	VIFx	32.3	135.0	st2

Supply Trunk Detail Table


Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st10	Peak AVF	97	164	0.077	470	8.0	0 x 0	ShtMetl	st7
st7	Peak AVF	325	417	0.077	764	10.0	0 x 0	ShtMetl	st6
st6	Peak AVF	375	449	0.077	572	12.0	0 x 0	ShtMetl	st5
st5	Peak AVF	534	556	0.077	708	12.0	0 x 0	ShtMetl	st1
st2	Peak AVF	151	131	0.107	566	7.0	0 x 0	ShtMetl	st4
st4	Peak AVF	266	244	0.107	761	8.0	0 x 0	ShtMetl	st1
st11	Peak AVF	186	227	0.087	850	7.0	0 x 0	ShtMetl	st7
st1	Peak AVF	800	800	0.077	453	18.0	0 x 0	ShtMetl	

Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	20x11	375	449	197.0	0.077	572	12.0	0x 0		ShMt	rt3
rb5	10x10	206	161	130.5	0.116	590	8.0	0x 0		ShMt	rt1
rb3	10x10	144	128	126.5	0.120	539	7.0	0x 0		ShMt	rt4
rb4	6x10	75	62	185.5	0.082	384	6.0	0x 0		ShMt	rt3

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt3	Peak AVF	450	511	0.077	650	12.0	0 x 0	ShtMetl	rt2
rt1	Peak AVF	800	800	0.077	573	16.0	0 x 0	ShtMetl	
rt2	Peak AVF	594	639	0.077	598	14.0	0 x 0	ShtMetl	rt1
rt4	Peak AVF	144	128	0.120	413	8.0	0 x 0	ShtMetl	rt2



Job #: SEG 0314-077W
Performed by Tracy Savoy for:

Right-Sized Residence
ACCA Manual J Street
Oak Park, IL 60301

Savoy Engineering Group

Phone: (801) 949-5337
www.load-calculations.com

Scale: 1 : 81

Page 1
Right-Suite® Universal 2013
13.0.09 RSU13868
2014-Mar-18 18:57:36
...port for website\Right-Sized.rup