

Continued from Previous Page

Lab Sample#: 1810090-01	Sample Address:								
Sample Matrix: NP-H2O	Sample Point:	Surface:							
Description: SAND POND-2018	Sample Date: 06/13/2018	Sample Time: 08:40:00							
<u>Test (Method)/Analyte</u>	<u>Result</u>	<u>Unit</u>	<u>Qualifiers</u>	<u>MCL</u>	<u>RL</u>	<u>High Limit</u>	<u>Low Limit</u>	<u>Analysis Date</u>	<u>Analyst</u>
E. coli (9223 B)	2	MPN/100r	J	235	1			06/14/2018 12:42:00	J.C.

E.coli result is approximate because sample exceeded 8-hour holding time for non-potable water.

Attached By D.M.

Date 06/15/2018

Time 14:16:32

Continued from Previous Page

## Units & Measurement

"mg/L" = Milligrams per liter;

"ug/L" = Micrograms per Liter;

"mg/Kg" = Milligrams per Kilogram;

"ug/Kg" = Micrograms per Kilogram;

"NTU" = Nephelometric Turbidity Units;

"pCi/L" = Picocuries per Liter;

The MCL, Maximum Contaminant Level is listed for comparing your results with recommended levels.  
In the "Qualifier" column, an " \* " is placed to indicate any results that **exceed** this MCL.

**If there are no " \* " in the "Qualifier" column, your water is considered satisfactory for those tests.**

All solid results are reported on a "Dry Weight" basis.

RL-Reporting Limit is the lowest concentration which can be reliably reported on a routine basis.

"<" = Less than      ">" = Greater than

MCL - Maximum Contaminant Level is the highest level allowed by EPA for public water supplies. Also used here as the maximum advisory limit set by the Maine Centers for Disease Control and Prevention.

**Note:** Results below the advisory limit, including < and J are considered satisfactory for that parameter.

## Disclaimer

Your report consists of the number of pages listed on the cover page. Any attachments after the last numbered page are for informational purposes only and not part of the formal report.


The results in this report are for the submitted sample(s) only.

This report shall not be reproduced, except in full, without written permission from the Maine Health and Environmental Testing Laboratory.

### Qualifiers Legend:

#### User selectable

Code	Description
*	> Secondary Limit
**	> MCL
~	Approximately
Ach	Above Calibration Curve
B	Blank Contamination
Hi	
J	<RL>MDL
Lo	
Nan	Not Analyzed
Nc	Not Confirmed
Nt	NonTarget Compound
R	Rejected
Rec	Recovery
T	Temperature does not meet criteria
U	Undetected



Maine Center for Disease Control and Prevention

An Office of the Department of Health and Human Services

Paul R. LePage, Governor Ricker Hamilton, Acting Commissioner

Department of Health and Human Services Health and Environmental Testing Laboratory

221 State Street #12 State House Station Augusta, ME 04333-0012 United States Of America Phone: (207)287-2727 Fax: (207)287-6832 TTY: 1-800-606-0215

TOWN OF BALDWIN 534 PEQUAWKET TRAIL WEST BALDWIN ME 04091

Logged: 6/14/2018 3:08:09PM

Folder #: 1810090

Office Use Only: Do Not Bill WALK-IN\_T

Released: 6/18/2018

No. of Samples in Folder:(1)

1810090-01

CERTIFICATION

The HETL hereby certifies that all test results for this sample were analyzed by the method listed, including preservation, preparation, and holding times, unless otherwise indicated.

Kenneth G. Pote, PhD., Director

Richard French, Quality Assurance Officer

If we can be of further assistance to you, Please Call us at 287-1716

Approved by:

Handwritten signature of Christopher Montagna

Christopher Montagna Inorganics Supervisor/Chemist III