



ISA Delhi Section

Setting the Standard for Automation™

Vibration Monitoring System

Forbes Marshall Pvt. Ltd.

ISA-D: "Fertiliser , Food and Pharma Symposium-2023"

Copyright 2022. ISA. All rights reserved. www.isadelhi.org

Agenda

- Brief Introduction
- Basic and benefits for growth
- Offering range meeting the industrial need
- Q&A

Brief Introduction

- 1926 : Company Started
- 5 Manufacturing Facilities in India.
- 300+ Engineering Products & Solutions.
- 1515 Trained Professionals with 300 Sales & Services Engineers.
- 90 R&D Professionals.
- 3 Joint Venture Companies.
- 15000+ Customers in India & Globally.



Process automation & control instrumentation



Flow & Level

Flow Meters : Magnetic , Ultrasonic, Mass Flow, Variable Area & Vortex. Level : Radar, Magnetic, Ultrasonic & Vibration.



Valves

Control & Process Valves, Safety Valves, DeSuperheater, Stop and Check Valves, High Pressure Valves, Turbine Bypass Valves



Emission Monitoring

Insitu CO,SO2, Nox Gas Monitors & Dust Monitors for Online stack Emission Monitoring



Vibration Monitoring





Vibration Sensors Monitoring System Analysis & Diagnosis Software Vibration Audit Services.

M/s Shinkawa Electric Co. Japan

- 75 Year Old Company
- API – Task Force Member (API-670)
- Exclusively Represented in India
by Forbes Marshall Pvt Ltd.




Basic , Benefits for Growth



Scale Factors on a Sinusoidal Vibration Waveform.


Peak = 1.0
 RMS = 0.707 x Peak
 Average = 0.637 x Peak
 Peak-to-Peak = 2 x Peak



1. EX/Atex Certified
2. Geo (Anticorrosive later coated)
3. API-670 Compliance are taken care

Approvals

- PDIL
- EIL
- IFFCO Kalol
- CCOE



PDIL
पी डी आई एल
Approved Product

PNMM/REGN/ P3452
Date : 07-04-2016

M/s SHINKAWA ELECTRIC COMPANY LTD.
3RD FLOOR, SHINKOJIMACHI BLDG,3-3 KAJOM
TOKYO 1020083
JAPAN
JAPAN

Dear Sirs,

Subject : VENDOR

We are pleased to inform you that you have been registered for the supply of the item(s) described below :

ITEM CODE	ITEM DESCRIPTION
310901	MACHINE MONITORING SYSTEM

This enlistment is valid for your facility at :
SHINKAWA SENSOR TECHNOLOGY INC.,
HIGASHI-HIROSHIMA, HIROSHIMA 739015


Please refer the above reference number in all correspondence.

Kindly note that this enlistment is subject to satisfactory completion of the above mentioned items when ordered for our various projects.

Further, it may be noted that any change in the product range, location of Works / Sales office, Management/ Organisation structure etc. shall be intimated to us immediately along with relevant documents for our necessary action. In case, information to any of the above referred changes is not intimated timely, the enlistment with us is liable to be cancelled. Your performance shall be reviewed for continuation of your enlistment with PDIL. Enlistment with PDIL shall not guarantee any regular flow of enquiries.

This registration is valid till 07-04-2021. You shall contact us at least 180 days in advance for revalidation of your registration with us, failing which your name may be deleted from our vendors list.

Thanking You.

Yours faithfully,

(P.R. SAHU)
Addl. General Manager(MM)

PUR/Vendor Reg/2012/

RECEIVED
25 OCT 2013
FORBES MARSHALL GROUP
M.I.D.C., PIMPRI, PUNE - 18

09 July 2013
03 SEP 2013

FORBES MARSHALL PVT LTD
A - 34/35 H - BLOCK, MID C INDUSTRIAL ESTATE,
PIMPRI, PUNE
MAHARASHTRA 411018

Dear Vendor

Please refer to your application for Registration with M/s. Indian Farmers

1 We are pleased to inform you that on the basis of documents internal, vendor evaluation IFFCO-Kalol has registered/your supplier/service provider with effect from the date of issue of this below:

Supplier Code	223831
Supplier Site Name	PUNE

List of Categories:

I131-KALOL	pH/CONDUCTIVITY SIMULATOR
I431-KALOL	VIBRATION MONITORING SYSTEM
I746-KALOL	FORBES MARSHALL MAKE INSTRUMENTS
M484-KALOL	SAFETY RELIEF VALVES - NON CRITICAL
M593-KALOL	GATE/GLOBE/CHECK VALVES : CS/SS/AS/
MK81-KALOL	STEAM TRAP- CRITICAL APPLICATION (IMI
T104-KALOL	DESUPERHEATER SYSTEM : DESIGN AND

2 This Supplier Code should be quoted on all future correspondence

3 The RFQs/Enquiries are floated ON-LINE only. You have to visit against our e-proc tender, whenever the RFQ is placed on our through e-mails & SMS which are registered with us. The E-proc Kalol and 011-42592728 for New Delhi.




ENGINEERS INDIA LIMITED
(A Govt. of India Undertaking)

पंजीकृत कार्यालय : इंडीयन रिफाइनरी प्रम. 1, रीफाइनरी कामप्लेक्स, नई दिल्ली 110066
Regd. Office : Engineers India Bhavan, 1, Bhikaji Cama Place, New Delhi-110066

Procurement Development Department

Ref. 4594/PDD/RE/S814 14th March, 2016

M/s Shinkawa Electric Company Ltd.
Shinkojimachi Bldg, 3F
4-3-3 Koj-maji
Chiyoda-Ku.



GOVERNMENT OF INDIA
MINISTRY OF COMMERCE & INDUSTRY
PETROLEUM AND EXPLOSIVES SAFETY ORGANISATION (PESO)
(Formerly Department of Explosives)
CGO COMPLEX SEMINARY HILLS
NAGPUR 440006
SPEED POST

Letter No: A/PHQ/MH/104/2975(P315797)
Email : xplivesives@explosives.gov.in
Phone/Fax No.2510248/2510577
Dated : 4/4/2013

To
M/s. Shinkawa Sensor Technology Inc.
4-22 Yoshikawa Kogyodanchi
Higashihiroshima, 759-0153, JAPAN.

Sub-Approval of Intrinsically safe type Displacement transducer under Petroleum Rules, 2002.

Dear Sir(s),

Please refer to letter No SAM/CCE/Shinkawa/Jan-2013 dated 04/01/2013 from M/s. Forbes Marshall Pvt. Ltd., Pune on the above subject.

The following Intrinsically Safe equipment(s) manufactured by you according to EN 60079-0 : 2009 & EN 60079-11 : 2012 standards and covered under LCIE, France Test reports mentioned below is approved for use in Zone 0 and Zone 1 of Gas Group IIC hazardous areas coming under the purview of the Petroleum Rules, 2002 administered by this Organization.

Sr.No	Description	Safety Protection	CCEs Identification Number	Test House	Test Report No.	Drawing Numbers
1	Displacement Transducer Type Ex ia IIC T4 VK-...-RD-...-FK-...-GK-...	Ga	P315797/1	LCIE, France	LCIE 03 ATEX 6222 X (Supplement 7) Dt.24/10/2012	As per Test Report

This Approval is granted subject to observance of the following conditions:-

- The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the LCIE, France Test Reports referred to above
- The equipment shall be used only with approved type of accessories and associated apparatus
- Each equipment shall be used only in conjunction with the approved Intrinsically Safe barriers
- Each equipment shall be marked either by raised lettering cast integrally or by plate attached to the main structure to indicate conspicuously
 - Name of the manufacturer
 - Name and number by which the equipment is identified
 - Number & Date of the test Report of the LCIE, France applicable to the equipment
 - CCEs Identification Number of this letter by which use of the apparatus is approved
- A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the LCIE, France test report and is identical with the one tested and certified at LCIE, France shall be furnished with each equipment
- The customer shall be supplied the copy of this letter, an extract of the conditions and maintenance schedule, if any recommended by LCIE, France in their test reports and copy of instructions book...

CELLENCE THROUGH PEOPLE
pe@eail.com
http://www.engineersindia.com

ISO 9001:2008
APPROVED BY PDS
IATF
NEW DELHI

API-670 Parameters

Contact Type

1. Casing Vibration
2. Radial shaft displacement
3. Axial shaft displacement
4. Piston rod drop
5. Differential expansion
6. Rotor speed
7. Rotor acceleration
8. Rotor over speed
9. Phase reference

Non
Contact
Type

Linear Motion



10. Valve position
11. Casing expansion
12. Critical machine temperature
13. Documentation

Gen Winding Temp


API-670 Limiting values

Temperature			Accuracy Requirements as a Function of Temperature	
Components	Testing Range	Operating Range	Within Testing Range	Outside Testing Range but Within Operating Range
Proximity probes	0°C to 45°C (32°F to 110°F)	-35°C to 120°C (-30°F to 250°F)	Incremental Scale Factor: ± 5% of 7.87 mV/μm (200 mV/mil)	Incremental Scale Factor: An additional ±5% of the testing range accuracy
Extension cables	0°C to 45°C (32°F to 110°F)	-35°C to 65°C (-30°F to 150°F)	Deviation from Straight Line: within ±25.4 μm (±1 mil) of the best fit straight line at a slope of 7.87 mV/μm (200 mV/mil)	Deviation from Straight Line: within ±76 μm (±3 mils) of the best fit straight line at a slope of 7.87 mV/μm (200 mV/mil)
Oscillator-demodulators	0°C to 45°C (32°F to 110°F)	-35°C to 65°C (-30°F to 150°F)	Minimum linear range: 2 mm (80 mils)	Minimum linear range: same as for testing range
Accelerometers and accelerometer extension cables	20°C to 30°C (68°F to 86°F)	-55°C to 120°C (-65°F to 250°F)	<ul style="list-style-type: none"> Principal Axis Sensitivity: 100 mV/g ±5% Amplitude Linearity: 1% from 0.1 g pk to 50 g's pk Frequency Response: ±3 dB from 10 Hz to 10 kHz, referenced to the actual measured principal axis sensitivity. 	Principal Axis Sensitivity: 100 mV/g ±20%
Temperature sensors and leads	0°C to 45°C (32°F to 110°F)	-35°C to 175°C (-30°F to 350°F)	±2°C (±4°F) over a measurement range from -20°C to 150°C (0°F to 300°F)	±3.7°C (±7°F) over a measurement range from -20°C to 150°C (0°F to 300°F)
Monitor system components for measuring				
Radial Vibration, Axial Position, Piston Rod Drop, and Casing Vibration	0°C to 45°C (32°F to 110°F)	-20°C to 65°C (0°F to 150°F)	±1% of full scale range for the channel	Same as for testing range
Temperature			±1°C (±2°F)	Same as for testing range
Speed and Over speed				Same as for testing range

For Low Duty Machines



For Heavy Duty Machines



Zuary Agro Goa

Name of Machines: Syngas & Ammonia Compressor ,
TG Sets , Carbamate Pump (Old Monitor Replacements)
Products : SEC FK series, CA & CV series Sensors , VM-7B
Monitor

Key Factors :

Step 1 : Kept Old Sensors intact and installed Monitoring
System

Step 2 : Replaced Old Sensors with New API670 Sensors
including Ammonia Applications.

Zero Failures at Ammonia Probe since last 7 Years



Kribhco Surat

Name of Machines : Ammonia Compressors – 2 Sets
 (Old Monitors Replacements)
 Products : SEC FK series, CA & CV series Sensors , VM-7B Monitor
 Key Factors :
 Replaced Old Sensors with New API670 Sensors & Monitoring U
 Running Successfully since 2011.]



कृषक भारती कोआपरेटिव लिमिटेड
 पी. ओ. कृष्को नगर, सूरत-394 515 (गुजरात) भारत
KRISHAK BHARATI COOPERATIVE LIMITED
 P.O. KRIBHCO NAGAR, SURAT-394 515 (GUJARAT) INDIA

दूरभाष/Tel. : (0261) 2862766 to 68
 E-mail : piushkumar@kribhco.net

PURCHASE DEPTT.

LETTER OF INTENT

Date: 05.04.2023

LOI / PO no. 5019087

FORBES MARSHALL PVT. LTD.
 PLOT NO. B-85, PHASE-II, CHAKAN INDL. AREA
 VILLAGE SAVARDARI-CHAKAN, TAL; KHED - 410501, DIST. PUNE
 GSTIN: 27AACF2630E1Z5

Kind Attn: Sh. Neel Naik Email: nnaik@forbesmarshall.com

Sub: Supply & Commissioning Assistance for Vibration Monitoring Systems and Field Sensors

कृषक भारती कोआपरेटिव लिमिटेड *OK-1058*
 4-1-11
 P.O. KRIHCO NAGAR, SURAT-394 515. (GUJARAT) INDIA
 (Purchase Dept.)

दूरभाष/Tel. : (0261) 2862763, 2862766 to 68
 फैक्स/Fax-Purchase: 91-0261-2861500
 फैक्स/Fax-General: 91-0261-2860283
 ग्राम/Gram: कृष्को नगर / KRIBHCO-SURAT
 E-mail: shah_db@kribhcosurat.com

KRISHAK BHARATI COOPERATIVE LIMITED
 P.O. KRIHCO NAGAR, SURAT-394 515. (GUJARAT) INDIA
 (Purchase Dept.)

P.S. DETAILED ORDER FOLLOWS

PURCHASE ORDER

M/S. SHINKAWA ELECTRIC CO. LTD.,
 SHINKOJIMACHI BUILDING,
 3F, 4-3-3 KOJI-MACHI, CHIYODA-
 KU, TOKYO
 JAPAN
Fac + 81-3-3262-2171
+ 81-3-3263-4417

Purchase Order No
HP/22/0826/OG72011///PO33920
 Dated: 03/01/2011

(THIS PURCHASE ORDER NO. SHOULD APPEAR IN
 ALL OTHER DOCUMENTS. INVOICE, PACKING LIST,
 D ALL OTHER DOCUMENTS ON EACH

MOM

MOM between M/S. Kribhco - Surat & M/S. Forbes Marshall Pvt. Ltd -
 Pune at Kribhco - Surat on 23rd Nov 2011.

Members present:

KRIBHCO FORBES MARSHALL
 Mr. C.J.SHAH Mr. Manoj Wagh
 Mr. P S Gandhi
 Mr. S D Purank

Reference: Commissioning of Vibration monitoring system using Shinkawa
 make Model VM-7B supplied against W.O. no.: HP/22/0824/CE-0140/ WO
 21809 dtd. 2.2.2011.

- Forbes Marshall representative Manoj Wagh reached site on 22nd Nov-2011.
- During shut-down, Kribhco has installed & terminated Vibration Monitoring rack VM7B & Display in Ammonia-1 plant on ammonia compressor 105 J.
- Configuration of VM-7H was checked, modified & verified as per documentation & customer's need.
- Simulation tests were carried out on all vibration, axial & speed measurements channels and also simulated test were made successfully to check alarms & tripping as per requirements.
- System is commissioned and now working satisfactorily.
- M/S. FMPL requested to revert in case of any problems during operation & assured to provide tech. support as & when required.

360.00 AIRPORT
 ON DATE OF P.O. SHOULD BE WITHOUT IMP.LIC. sure-II

ifications and be part of this P.O.

CO-OPERATIVE LTD.
3/1/11
 AGER (COMM)

For Forbes Marshall Pvt. Ltd. - Pune For Kribhco - Surat

GSFC Baroda

Name of Machines : Ammonia Compressor (Melamine 3)(Old Monitors Replacements)
Products : SEC FK series, CA & CV series Sensors , VM-7B Monitor
Key Factors :
Replaced Old Sensors with New API670 Sensors & Monitoring Units
Running Successfully : 2018.



GUJARAT STATE FERTILIZERS & CHEMICALS LIMITED
P.O.FERTILIZERNAGAR-391750 DIST. VADODARA
Phone: 2242051, 2242451, 2242851, 2242751, 2242541
Fax: 0265-2240966, 0265-2240119, 2242746(PURCHASE)
EMAIL: ho@gsfcltd.com

Page 1 of 8
[F.70:307.0]

Version: 0 of 0

Purchase Order No.: 4110048944/8163
Date : 13.03.2023
Vendor Code 112216 GST NO:27AAACF2630E1Z5
M/s FORBES MARSHALL PVT LTD,
PLOT NO. B-85, PHASE -II
CHAKAN INDUSTRIAL AREA
VILLAGE : SAVARDARI - CHAKAN
TA : KHED, DIST. PUNE
PUNE - 410501
Maharashtra - India
ksheladiya@forbesmarshall.com
Phone:9825000717

Dear Madam/Sir,
We refer to your Offer No. 626 Dated 04.08.2022 against our Enquiry No. 811001694 and are pleased to inform that we have accepted the rates offered by you. Please arrange to supply the goods shown here under strictly, according to the description and terms and conditions of our enquiry and this purchase order.



Minutes of Meeting between M/S. Forbes Marshall Pvt Ltd (FMPL) & M/s GSFC at Vadodara Site dated 28/09/2018.

Visit Date: 27-09-2018

Departure Date: 28-09-2018

Visit Type: Commissioning of Vibration Monitoring System (VMS) on ammonia compressor - Melamine 1 plant.

MEMBERS PRESENT:

M/s Forbes Marshall
Mr. Meghashyam

M/s GSFC Ltd.
Mr. A V Shah
Mr. R E Patel
Mr Harsh Brahmhatt

With reference to above details, M/s FMPL representative visited site and below activities were carried out & observation noted:

1. VMS Panel & rack - 1 no charged up with UPS 110V AC.
2. HMI Schneider installed & charged up.
3. Rack configuration verified & field erection inspection was carried out. Found ok.
4. Radial (4 - sensors/extension cable/driver) & axial (1- sensor/ext cable/driver) complete loop verified/tested ok from field side to Panel to HMI on TK3 kit. Relays & mA output also tested ok.
- 5 All the old bently sensors/cable/driver were replaced & installed with shinkawa - sensor/cable/driver on the same previous locations.
6. Thus Bently Nevada 7200 VMS was replaced with Shinkawa VMS VM7B system successfully.
7. The system is kept under observation & would be reported to FMPL in case of any issues or support required during operation stage.
8. Certain trending improvement In context to HMI is required by GSFC. A separate mail is initiated to the concerns and needs to be addressed on immediate basis.


M/s Forbes Marshall


M/S GSFC

Ashuganj Ferti. Bangladesh



Replacement of around 12 old BN 7200/3300 racks

- Latest VM-7 series Racks
- Ammonia compressor,
- Air compressor,
- Synthesis compressor,
- Alternator –I & II ,
- Carbamide pumps
- CO2 compressor

Eddy Current Probe System

- FL-202 : 2000 μm : 787 mV/100 μm
- FL-452 : 4500 μm : 3.94 mV/100 μm




FK-202F	- 2	- 1	- 1	-	/
	System cable length	Mounting plate	Terminal Block	Intrinsically safe	Geothermal spec.
	1 5 Meter	1 DIN Rail(35mm) Mount	1 Screw type terminal block (M4)	1 TIIS (Ex ia IIC T4)	Geo
	2 9 Meter	2 Screw mount (50.8×50.8mm)	2 Spring lock terminal	4 CSA C/US (Ex ia IIC T4)	
		3 Screw mount (92×31mm : For VK replacement)		5 ATEX (Ex ia IIC T4 Ga)	
		4 Screw mount Multi-pitch (50.8×50.8mm and 92×31mm)		7 NEPSI (Ex ia IIC T4)	
				8 KTL (Ex ia IIC T4)	
				B TS (Ex ia IIC T4 Ga)	

Eddy Current Probe System

	Standard code			Additional code		Spec.
Model	FL-202F08A-M2
Unthreaded length(L1)	00	0mm [Standard]
$L1 \leq L2 - 20\text{mm}$	01 to 23	10 to 230mm(10mm step) [Option]
Case length (L2)	02 to 05	20 to 50mm(10mm step) [Standard]
	06 to 25	60 to 250mm(10mm step) [Option]
Cable Length	05	0.5m [Standard]
	10	1.0m [Standard]
	20	2.0m [Option]
	50	5.0m [Option]


Intrinsic Safety




API-670 Vibration Monitoring & Protection



API-670 Vibration Monitoring & Protection



VM-760B
19-inch
Instrument Rack




Power Supply Modules
Network Comm. Modules
Local Comm. & Phase Marker Module



Monitor Modules

Relay Modules


API-670 Vibration Monitoring & Protection




Channel Bypassing for special needs



Vibration Analysis



All M/Cs






Channel Name	Time	RPM	Value/OA	Gap	1X Amp.	1X Phase deg.	2X Amp.	2X Phase deg.	0.5X Amp.	0.5X Ph. deg.
ABS VIB BRG 1-X	2017-06-23 14:00:41	2999.5	0.60 mm/s...		0.50 mm/s...		0.24 mm/s...		0.01 mm/s...	
ABS VIB BRG 1-Y	2017-06-23 14:00:41	2999.5	0.60 mm/s...		0.50 mm/s...		0.24 mm/s...		0.01 mm/s...	
REL SHFT VIB BRG 1-X	2017-06-23 14:00:41	2999.5	36.65 μ mP...	-8.4 V	35.02 μ mP...	51.4	0.37 μ mPP	14.1	1.09 μ mPP	177.3
REL SHFT VIB BRG 1-Y	2017-06-23 14:00:41	2999.5	35.71 μ mP...	-9.0 V	34.19 μ mP...	99.9	2.25 μ mPP	231.2	0.47 μ mPP	125.3
ABS VIB BRG 2-X	2017-06-23 14:00:41	2999.4	0.70 mm/s...		0.60 mm/s...		0.06 mm/s...		0.02 mm/s...	
ABS VIB BRG 2-Y	2017-06-23 14:00:41	2999.4	0.70 mm/s...		0.60 mm/s...		0.06 mm/s...		0.01 mm/s...	
REL SHFT VIB BRG 2-X	2017-06-23 14:00:41	2999.4	30.17 μ mP...	-5.3 V	29.34 μ mP...	167.2	0.74 μ mPP	31.5	0.59 μ mPP	114.7
REL SHFT VIB BRG 2-Y	2017-06-23 14:00:41	2999.4	39.31 μ mP...	-6.1 V	38.54 μ mP...	214.2	0.30 μ mPP	59.6	0.20 μ mPP	84.8
ABS VIB BRG 3-X	2017-06-23 14:00:41	2999.4	0.40 mm/s...		0.20 mm/s...		0.06 mm/s...		0.02 mm/s...	
ABS VIB BRG 3-Y	2017-06-23 14:00:41	2999.4	0.40 mm/s...		0.30 mm/s...		0.07 mm/s...		0.02 mm/s...	
REL SHFT VIB BRG 3-X	2017-06-23 14:00:41	2999.4	20.07 μ mP...	-9.0 V	19.18 μ mP...	299.0	2.96 μ mPP	9.7	0.17 μ mPP	13.8
REL SHFT VIB BRG 3-Y	2017-06-23 14:00:41	2999.4	14.60 μ mP...	-9.3 V	13.60 μ mP...	266.0	3.07 μ mPP	13.7	0.08 μ mPP	4.3
ABS VIB BRG 4-X	2017-06-23 14:00:41	2999.4	0.80 mm/s...		0.70 mm/s...		0.11 mm/s...		0.01 mm/s...	
ABS VIB BRG 4-Y	2017-06-23 14:00:41	2999.4	0.10 mm/s...		0.00 mm/s...		0.00 mm/s...		0.01 mm/s...	
REL SHFT VIB BRG 4-X	2017-06-23 14:00:41	2999.4	25.14 μ mP...	-8.9 V	24.12 μ mP...	47.9	5.21 μ mPP	196.3	0.13 μ mPP	53.3
REL SHFT VIB BRG 4-Y	2017-06-23 14:00:41	2999.4	18.87 μ mP...	-8.7 V	18.02 μ mP...	72.3	4.33 μ mPP	194.8	0.09 μ mPP	127.8
ABS VIB BRG 5-X	2017-06-23 14:00:41	2999.4	1.30 mm/s...		1.20 mm/s...		0.12 mm/s...		0.01 mm/s...	
ABS VIB BRG 5-Y	2017-06-23 14:00:41	2999.4	1.30 mm/s...		1.20 mm/s...		0.12 mm/s...		0.00 mm/s...	
REL SHFT VIB BRG 5-X	2017-06-23 14:00:41	2999.4	70.56 μ mP...	-8.1 V	70.09 μ mP...	102.0	6.00 μ mPP	126.0	0.22 μ mPP	97.5
REL SHFT VIB BRG 5-Y	2017-06-23 14:00:41	2999.4	13.95 μ mP...	-8.2 V	12.13 μ mP...	106.7	5.41 μ mPP	129.2	0.10 μ mPP	71.0
ABS GEN F BRG 6-X	2017-06-23 14:00:41	2999.4	2.20 mm/s...		2.20 mm/s...		0.22 mm/s...		0.02 mm/s...	
ABS GEN F BRG 6-Y	2017-06-23 14:00:41	2999.4	2.10 mm/s...		2.10 mm/s...		0.22 mm/s...		0.01 mm/s...	
REL SHFT GEN F BRG6X	2017-06-23 14:00:41	2999.4	68.03 μ mP...	-8.4 V	66.85 μ mP...	213.0	12.63 μ mPP	150.0	0.13 μ mPP	79.8


- Trend Plot
- Long Term Trend Plot
- Bar Graph
- Spectrum Plot
- Waveform Plot
- Orbit & Waveform Plot
- Waterfall Plot
- Polar Plot
- Shaft Centerline Plot
- X-Y Plot
- S-V Plot
- Bode Plot
- Cascade Plot
- Full Spectrum Plot
- Full Waterfall Plot
- Full Cascade Plot
- Campbell Plot
- Bearing Analysis
- Transient Trend Plot
- Transient Spectrum Plot
- Transient Waveform Plot
- Transient Orbit & Waveform Plot
- Transient Waterfall Plot
- Transient Polar Plot
- Transient Shaft Centerline Plot
- Transient X-Y Plot
- Transient S-V Plot
- Transient Bode Plot
- Transient Cascade Plot
- Transient Full Spectrum Plot
- Transient Full Waterfall Plot
- Transient Full Cascade Plot
- Transient Campbell Plot
- Alarm Trend Plot
- Alarm Spectrum Plot
- Alarm Waveform Plot
- Alarm Full Spectrum Plot
- Copy to Clipboard
- CSV
- Close

Amp.	nX2 Phase deg.	nX3 Amp.	nX3 Phase deg.	nX4 Amp.	nX4 Phase deg.	IX1 Amp.	IX2 Amp.	S(p-p)max	Inner Race	Outer Race	Bo
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		75.76 μ ...		
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		75.76 μ ...		
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		76.37 μ ...		
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		74.99 μ ...		
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		37.56 μ ...		
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		37.44 μ ...		
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		81.42 μ ...		
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		81.42 μ ...		
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
mm/...		0.00 mm/...		0.00 mm/...		0.00 mm/...	0.00 mm/...				
μ m...	0.00	0.00 μ m...	0.0	0.00 μ m...	0.0	0.00 μ m...	0.00 μ m...		120.79 μ ...		


Drag and drop navigation



Plant wise remote analysis system




FM Vib Assist Vibration Analysis Software



Our Wireless Solution

- Wireless sensors
- Tri-Axial
- Wirepass based
- Gateway communicator
- Cloud based solution
- Common software for wired/wireless system



Our Wireless Solution

Tri-axial Sensor with Temperature measurement

Frequency range : up to 6.3kHz (+/-3dB)

Sampling rate : 26.6 KHz /16bit

Configurable full-scale : $\pm 2/\pm 4/\pm 8/\pm 16g$

Temperature measurement : -40°C to $+85^{\circ}\text{C}$

Resolution: 0.1°C

Accuracy: $\pm 2^{\circ}\text{C}$ (mounting dependent)

Repeatability: $\pm 0.1^{\circ}\text{C}$

Velocity: RMS, PEAK, P2P

Acceleration: RMS, PEAK, P2P, Kurtosis, Crest

Sample amount: 4096 max

Lines of resolution: 1600 lines max


Averages: configurable up to 9

Overlap: 0 to 100%

Windowing: optional Hanning



General schematic



Plus these too

- Rule Based Diagnostics
- Time Based Auto Diagnostics
- Training @ Our place for vibration analysis

आशा