

Tuesday, March 23, 2023

**Town of Arnaudville  
Utility Dept Update**

**February - 2023**

WATER – The entire water system was flushed during the month of February. The monthly Safe Drinking Water Act daily chlorine residual logs were verified by Todd Abshire and are on file in the utility office as required by law.

WASTEWATER – There aren't any major issues to report regarding the town's wastewater system. The monthly flow records were faxed to HoPak Laboratories to verify flow in accordance with our discharge permit, as well as all analytical results being examined, reported, and filed in the utility department files.

GAS – Two employees were sent to Natural Gas training during the month of February. Lee Mallet requalified (we are required to requalify every 3 years) and Steve Bourque was initially qualified. With Steve's qualification completion, all utility department personnel are qualified and their qualification records are on file in the utility department office. Pipeline Safety will be performing a "Comprehensive Inspection" on the entire gas system during the month of April. The utility department is in the process of preparing for the inspection and we do not anticipate any major issues during preparation and inspection. The gas system is operating near 40 pounds of inlet pressure at the Cypress Station and 40 psi at the Koch Station.

Todd Abshire  
Superintendent, Town of Arnaudville

February 2023  
Work Order Report

	Gas	Water	Sewer	Gas	Water	Gas	Gas	Water	Water	DOT			Water (MGD)	Sewer (MGD)	
	Tap	Tap	Tap	Leak	Leak	On	Off	On	Off	Tickets	Misc	Total	Produced	Treated	Comments
1										1	3	4	0.331	0.167	equipment repairs
2											1	1	0.329	0.285	
3											1	1	0.348	0.479	
4												0	0.344	0.287	Saturday
5												0	0.336	0.149	Sunday
6	1									3	1	5	0.354	0.114	reading meters
7										4	2	6	0.372	0.071	reading meters
8										2	1	3	0.363	0.092	reading meters
9										1	3	4	0.416	0.362	reading meters
10										4	2	6	0.358	0.339	reading meters
11												0	0.347	0.172	Saturday
12												0	0.317	0.3	Sunday
13										2		2	0.338	0.157	meter re-read/flush
14										3		3	0.41	0.107	meter re-read/flush
15										5		5	0.408	0.113	flushing
16										4	3	7	0.454	0.12	flushing
17											1	1	0.405	0.726	flushing
18											1	1	0.216	0.168	Saturday/flushing
19											1	1	0.356	0.198	Sunday/flushing
20												0	0.367	0.138	holiday
21											1	1	0.404	0.122	flushing
22						1	6	1	9			17	0.413	0.116	disconnects/flushing
23										3	1	4	0.351	0.108	flushing
24											1	1	0.484	0.103	flushing
25												0	0.369	0.093	Saturday
26												0	0.435	0.09	Sunday
27										2	5	7	0.403	0.091	cutting grass
28	1									1	3	5	0.458	0.068	
<b>Total</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>9</b>	<b>35</b>	<b>31</b>	<b>85</b>	<b>10.486</b>	<b>5.335</b>	