



| CUSTOMER DATA | | |
|------------------------------------|----------|-----------|
| CUSTOMER: WESTINGHOUSE ELEC. CORP. | | |
| CUST. ORDER NO.: 489461 | | |
| ITEM: | | |
| DUTY: GPM: 2150 | TDH: 90' | RPM: 1770 |
| SERVICE WATER | | |

| PUMP | |
|----------|-----------------------------------|
| PART NO. | DESCRIPTION |
| 1 | DISCHARGE VENT (PLUGGED) 1/2" NPT |
| 2 | DRAIN 1/2" NPT |
| 3 | DISCHARGE COLUMN - 10" |
| 4 | PACKED TEN NUT BRG. |
| 5 | |
| 6 | |
| 7 | |
| 8 | |
| 9 | |
| 10 | |
| 11 | |
| 12 | |

| MOTOR | | |
|------------|-----------------|-------------|
| MAKE: US | | |
| FRAME: | ENCLOSURE: TEPC | |
| TYPE: VHS | HP: 75 | RPM: 1800 |
| VOLTS: 460 | PHASE: 3 | CYCLES: 60 |
| AA= 3 | AB= 15 1/8 | AC= 12 1/4 |
| AF= 4 | AG= 36 1/8 | BV= 12 5/16 |

| WEIGHTS | |
|---------------|--------------|
| PUMP: | 1300# APPROX |
| DRIVER: | 700 " |
| TOTAL WEIGHT: | 2000# APPROX |

| REVISIONS | | DIMENSIONS ARE IN INCHES | | YES DNO | |
|-----------|-------------|--------------------------|----|-----------|----|
| LTR | DESCRIPTION | DATE | BY | DATE | BY |
| A | ADDED WTS. | 20 SEP 89 | BH | 10 AUG 89 | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

| BYRON JACKSON® | |
|--------------------------|--|
| TULSA OPERATIONS | |
| DRAWING TITLE | |
| 16 GL ONE STAGE YTP | |
| DRAWING NO. / SERIAL NO. | |
| SK-891-A-0601 | |