

Hay

STATE OF CALIFORNIA

**DOMESTIC WATER SUPPLY PERMIT**

Issued To:

**Wynola Water District  
Water System Number 3701837**



**By The  
County of San Diego  
Department of Environmental Health**

**Land and Water Quality Division  
Small Drinking Water System Program**

County of San Diego Annual Operating Permit: LSWs-381837  
System Address: 4839 Glenside Road, Santa Ysabel, CA 92070  
System Classification: Untreated Community Public Water System

**WHEREAS:**

1. Wynola Water District submitted an application to the County of San Diego, Department of Environmental Health (DEH), to operate a community public water system. The application was submitted in accordance with California Health and Safety Code, Section 116525.
2. This public water system known as Wynola Water District is located at 4839 Glenside Road, Santa Ysabel, CA 92070.
3. The legal owner, Wynola Water District, is responsible for compliance with all statutory and regulatory drinking water requirements and the conditions set forth in this permit.
4. This public water system is designed to provide potable water for the daily use of 71 residential homes of Wynola Estates which serves approximately 120 people. The system has five active ground water sources: well 3 (PS code 3701837-003), well 7 (PS code 3701837-007), well 9 (PS code 3701837-009), well 10 (PS code 3701837-010) and well 11 (PS code 3701837-011). Storage consists of one 65,000-gallon above ground storage tank and one 45,000-gallon above ground storage tank.
5. The County of San Diego, Department of Environmental Health, has evaluated the information submitted by the Wynola Water District water system and has conducted an inspection of the Wynola Water District water system.